



origin

DOORS AND WINDOWS

PAS 24 CERTIFICATES

2.328.3

CERTIFICATE OF PAS 24

OB-36+

PRODUCT: ORIGIN EXTERNAL DOOR OB-36+

SUMMARY OF TESTING PROCEDURE:

PAS 24: 2022 - CLAUSE ANNEX A, B4.3, B.4.4.2, B.4.4.3,
B.4.4.4, B.4.5, B.4.6, B.4.8 AND B.4.9.2.2

RESULTS:

PASS

PASSED PAS 24: 2022 FOR THE REQUIREMENTS OF BOTH 3-STAR KEY
REMOVABLE AND THUMBTURN CYLINDERS.

TO COMPLY, A BS EN 356 P1A CERTIFIED GLASS UNIT MUST BE INSTALLED.

TESTED BY: BUILD CHECK

REFERENCE: W24141-11

DATE: NOVEMBER, 2024

CERTIFICATE OF PAS 24

OB-49

PRODUCT: ORIGIN EXTERNAL DOOR OB-49

SUMMARY OF TESTING PROCEDURE:

PAS 24: 2022 - CLAUSE ANNEX A, B4.3, B.4.4.2, B.4.4.3, B.4.4.4, B.4.5, B.4.6, B.4.8 AND B.4.9.2.2

RESULTS:

PASS

PASSED PAS 24: 2022 FOR THE REQUIREMENTS OF BOTH 3-STAR KEY REMOVABLE AND THUMBTURN CYLINDERS.

TO COMPLY, A BS EN 356 P1A CERTIFIED GLASS UNIT MUST BE INSTALLED.



TESTED BY: BUILD CHECK

REFERENCE: W24141-16

DATE: NOVEMBER, 2024

CERTIFICATE OF PAS 24

OB-72

PRODUCT: ORIGIN EXTERNAL DOOR OB-72

SUMMARY OF TESTING PROCEDURE:

PAS 24: 2022 - CLAUSE ANNEX A, B4.3, B.4.4.2, B.4.4.3, B.4.4.4, B.4.5, B.4.6, B.4.8 AND B.4.9.2.2

RESULTS:

PASS

PASSED PAS 24: 2022 FOR THE REQUIREMENTS OF BOTH 3-STAR KEY REMOVABLE AND THUMBTURN CYLINDERS.

TO COMPLY, A BS EN 356 P1A CERTIFIED GLASS UNIT MUST BE INSTALLED.



TESTED BY: BUILD CHECK

REFERENCE: W24141-15

DATE: NOVEMBER, 2024

CERTIFICATE OF PAS 24

OW-70

PRODUCT: ORIGIN WINDOW OW-70

SUMMARY OF TESTING PROCEDURE:

PAS 24: 2022 - CLAUSE C4.3, C.4.4.2, C4.4.3, C.4.5,
C.4.6, C.4.7

RESULTS:

PASS

TO COMPLY, A BS EN 356 P1A CERTIFIED GLASS UNIT MUST BE INSTALLED.



TESTED BY: BUILD CHECK

REFERENCE: W24141-5

DATE: JULY, 2024



DOORS AND WINDOWS

CERTIFICATE OF PAS 24

OW-80

PRODUCT: ORIGIN WINDOW OW-80

SUMMARY OF TESTING PROCEDURE:

PAS 24: 2022 - CLAUSE C4.3, C.4.4.2, C4.4.3, C.4.5,
C.4.6, C.4.7

RESULTS:

PASS

TO COMPLY, A BS EN 356 P1A CERTIFIED GLASS UNIT MUST BE INSTALLED.



TESTED BY: BUILD CHECK

REFERENCE: W24141-6

DATE: JULY, 2024



DOORS AND WINDOWS

CERTIFICATE OF PAS 24

PATIO SLIDER

PRODUCT: ORIGIN SLIDING DOOR OS-29

SUMMARY OF TESTING PROCEDURE:

PAS 24: 2016 - CLAUSE ANNEX A, B4.3, B.4.4.2, B.4.4.3, B.4.4.4, B.4.5, B.4.6, B.4.7, B.4.8 AND B.4.9.2.2

RESULTS:

PASS

PASSED PAS 24: 2016 FOR THE REQUIREMENTS OF BOTH 3-STAR KEY REMOVABLE AND THUMBTURN CYLINDERS.

TO COMPLY, A BS EN 356 P1A CERTIFIED GLASS UNIT MUST BE INSTALLED.

TESTED BY: Build Check Ltd

DATE: January, 2022

SIGNED: *D. Ginger*



DOORS AND WINDOWS

CERTIFICATE OF PAS 24

PATIO SLIDER

PRODUCT: ORIGIN SLIDING DOOR OS-77

SUMMARY OF TESTING PROCEDURE:

PAS 24: 2016 - CLAUSE ANNEX A, B4.3, B.4.4.2, B.4.4.3, B.4.4.4, B.4.5, B.4.6, B.4.7, B.4.8 AND B.4.9.2.2

RESULTS:

PASS

PASSED PAS 24: 2016 FOR THE REQUIREMENTS OF BOTH 3-STAR KEY REMOVABLE AND THUMBTURN CYLINDERS.

TO COMPLY, A BS EN 356 P1A CERTIFIED GLASS UNIT MUST BE INSTALLED.

TESTED BY: Build Check Ltd

DATE: January, 2022

SIGNED: *D. Ginger*

CERTIFICATE OF PAS 24 ENTRANCE DOOR DOOR

PRODUCT: ORIGIN ENTRANCE DOOR OB-72

SUMMARY OF TESTING PROCEDURE:

PAS 24: 2016 - CLAUSE ANNEX A, B4.3, B.4.4.2, B.4.4.3,
B.4.4.4, B.4.5, B.4.6, B.4.8 AND B.4.9.2.2

RESULTS:

PASS

PASSED PAS 24: 2016 FOR THE REQUIREMENTS OF BOTH 3-STAR KEY
REMOVABLE AND THUMBTURN CYLINDERS.

TO COMPLY, A BS EN 356 P1A CERTIFIED GLASS UNIT MUST BE INSTALLED.



TESTED BY: Build Check Ltd (securedbydesign.com/member-companies/sbd-members)

DATE: August, 2019

SIGNED: *D. Ginger*